



Report Number: 0133
Issued: 03/2009
Expires: 03/2010

DIVISION: 06 Wood and Plastics
Section: 06090 Wood and Plastic Fastening

UNIVERSAL FASTENER OUTSOURCING, LLC
3980 W. WEDINGTON DR #14
FAYETTEVILLE, ARKANSAS 72704
(800) 352-0028 or (479) 443-9292
www.911-nails.com info@911-nails.com

EVALUATION SUBJECT:

UFO BALLISTIC NAILSCREWS®

U.S. Patent Application No.: 11/725,967
Canada Patent Appl. No.: 2,583,890

ADDITIONAL LISTEES:

SENCO PNEUSCREW™
TYREX PNEUSCREW™

SENCO PRODUCTS, INC.
4270 IVY POINTE BLVD
CINCINNATI, OH 45245
(800) 543-4596
www.RexTool.com
GBohart@RexTool.com

1.0 EVALUATION SCOPE

1.1 Compliance with the following codes:

- 2006 International Building Code® (IBC)
- 2006 International Residential Code® (IRC)

1.2 Evaluated in accordance with:

- ICC AC 120 dated March 2006

Property Evaluated:

Structural

2.0 USES

UFO Ballistic Nailscrews® & Senco TyRex Pneuscrews™ are used as a substitution for nails in horizontal and vertical diaphragms (shear walls). Nailscrew®/Pneuscrew™ substitution in vertical diaphragm applications resisting seismic loads are outside the scope of this report.

3.0 DESCRIPTION

The UFO Ballistic Nailscrews® & Senco TyRex Pneuscrews™ are nominally 2-1/4 inches (57.5 mm), 2-1/2 inches (63.5 mm), and 3 inches (76.2 mm) in length and have a 0.270 inch to 0.275 inch (6.98 mm) diameter full round head. The shank has three identifiable sections. The first shank section is smooth, round, measures 1/2 inch (12.7 mm) in length for the 2-1/4 and 2-1/2 inch sizes and 5/8 inch (15.9 mm) for the 3 inch size from the head to midsection, and has a nominal diameter of 0.113 inch (2.9 mm). The second section measures 1-1/4 inches (31.8 mm), 1-1/2 inches (38.1 mm), and 1-7/8 inches (47.6 mm) in length for the three sizes respectively from the smooth round shank to the tip and is composed of deformed screw threads. The major diameter of the screw threads is 0.125 inch (3.1 mm) and the minor diameter is nominally 0.113 inch (2.8702 mm). The third section of the shank is the Ballistic point, reference Figure 1.

The proprietary head and shank geometries of the UFO Ballistic NailScrew® comply with the material requirements, physical properties, dimensional tolerances, workmanship, protective coating and finishes, and packaging requirements of ASTM F1667. The UFO Ballistic NailScrews® are manufactured from cold heading quality (CHQ) carbon steel wire rod grades 1018-1022 steel wire. They are heat treated and case hardened. The UFO Ballistic Nailscrews® & Senco TyRex Pneuscrews™ have minimum average bending yield strength, F_{yb}, of 100,000 psi (689.476 MPa).

EVALUATION REPORT



Report Number: 0133
Issued: 03/2009
Expires: 03/2010

4.0 DESIGN AND INSTALLATION

4.1 Design

4.1.1 Horizontal Diaphragms: Any of the above listed Ballistic NailScrews® are permitted to be substituted for the same nailing patterns as 8d common nails (2-1/2 x 0.131 inch [65x3.2 mm]) in 7/16" and 15/32" OSB horizontal diaphragms resisting wind or seismic loads referenced in tables: IBC 2006 Table 2306.3.1 and IRC 2006 Table R602.3(1).

4.1.2 Vertical Diaphragms: Any of the above listed Ballistic NailScrews® are permitted to be substituted for the same nailing patterns as 8d common nails (2-1/2 x 0.131 inch [65x3.2 mm]) in 7/16" and 15/32" OSB vertical diaphragms resisting wind loads referenced in tables: IBC 2006 Table 2306.4.1 and IRC 2006 Table R602.3(1).

4.2 Installation: UFO Ballistic NailScrews® & SENCO TYREX Pneuscrews™ must be installed in accordance with current manufactured published installation instructions, this report, and applicable requirements in the NDS, Section 11.1.5. The UFO Ballistic NailScrews® & SENCO TYREX Pneuscrews™ are either pneumatically driven or manually screwed in.

5.0 CONDITIONS OF USE

5.1 Use of Nailscrews®/Pneuscrews™ must comply with this report and the applicable code.

5.2 Diaphragm construction must conform to applicable provisions in the IBC and IRC.

5.3 The fasteners shall be driven flush with the face of the sheathing material.

5.4 Nailscrews®/Pneuscrews™ cannot replace nails in end conditions (i.e. driven parallel to grain in end of main member). This condition does not affect diaphragm/shearwall in typical construction.

5.5 The Nailscrews®/Pneuscrews™ are to be installed with a minimum edge and end distance of

3/8" (9.5 mm).

5.6 Where installation creates splitting of the wood prefabricated-drilling holes are required in accordance with the code for wood-screw installation.

5.7 The wood structural panel grade is permitted to be any of the following: Structural I grades; sheathing, single floor and other grades covered in DOC PS 1 and PS2.

5.8 This evaluation report does not address fastener corrosion when the fastener is installed in chemically treated wood.

6.0 EVIDENCE SUBMITTED

Data in accordance with the ICC-ES Acceptance Criteria for Wood Screws Used in Horizontal Diaphragms and Vertical Shear Walls (AC 120) dated March 2006

7.0 IDENTIFICATION

The screws are packaged in cartons bearing labels that provide the manufacturer name (UFO Ballistic Nailscrew® and/or Senco TyRex Pneuscrew™); a description; (type, length, & shank diameter); IAPMO ES Mark of Conformity and the Evaluation Report Number (ER-0133).



IAPMO #0133

A handwritten signature in black ink, appearing to read 'Amir' followed by a flourish.

Director of Evaluation Services

EVALUATION REPORT



Report Number: 0133
 Issued: 03/2009
 Expires: 03/2010

Figure 1:



Figure 2:

UFO no.	SENCO/TYREX no.	Description	Collation	Drive	Packed
HDNS214113YZPH	NPP4225	2 1/4" X .113" yellow zinc	20 deg. Plastic Strip	#2 phillips	1.5 M/case
HDNS214113YZPH4	N / A	2 1/4" X .113" yellow zinc	20 deg. Plastic Strip	#2 phillips	4-1M bx.
HDNS214113YZSQ	NSP4225	2 1/4" X .113" yellow zinc	20 deg. Plastic Strip	#2 square	1.5 M/case
HDNS214113YZSQ4	N / A	2 1/4" X .113" yellow zinc	20 deg. Plastic Strip	#2 square	4-1M bx.
WCNS214113YZPH	NPW4225	2 1/4" X .113" yellow zinc	15 deg. Wire Coil	#2 phillips	3.6 M/case
WCNS214113YZSQ	NSW4225	2 1/4" X .113" yellow zinc	15 deg. Wire Coil	#2 square	3.6 M/case
HDNS212113YZPH	NPP4250	2 1/2" X .113" yellow zinc	20 deg. Plastic Strip	#2 phillips	1.5 M/case
WCNS212113YZPH	NPW4250	2 1/2" X .113" yellow zinc	15 deg. Wire Coil	#2 phillips	3.6 M/case
WCNS212113YZSQ	NSW4250	2 1/2" X .113" yellow zinc	15 deg. Wire Coil	#2 square	3.6 M/case
PTHDNS212113PH	NPP4250D	2 1/2" X .113" PT2000® EG	20 deg. Plastic Strip	#2 phillips	1 M/case
PTWCNS212113SQ	NSW4250D	2 1/2" X .113" PT2000® EG	15 deg. Wire Coil	#2 square	.8 M/case
HDNS300113YZPH	NPP4300	3" X .113" yellow zinc	20 deg. Plastic Strip	#2 phillips	1 M/case
PTHDNS300113PH	NPP4300D	3" X .113 PT2000® EG	20 deg. Plastic Strip	#2 phillips	1 M/case
PTWCNS300113SQ	NSW4300D	3" X .113 PT2000® EG	15 deg. Wire Coil	#2 square	.8 M/case