



FIRESTABLE INSULATION COMPANY
36 Plains Road
Essex, CT 06426
(860) 767-8772
www.firestable.com

STABLEBASE MAX YIELD OPEN CELL SPRAY FOAM INSULATION

CSI Section:
07 21 00 Thermal Insulation

1.0 RECOGNITION

StableBase Max Yield Open Cell has been evaluated for use as spray foam insulation complying with IBC Section 2603, IRC Section R316, IECC Sections C303, C402, R303 and R402. The surface burning, physical properties, thermal resistance and applications in Type V construction and exterior walls of Types I-IV construction of StableBase Max Yield Open Cell spray foam insulation was evaluated to comply to the intent of the following codes and regulations:

- 2021, 2018, 2015, and 2012 International Building Code® (IBC)
- 2021, 2018, 2015, and 2012 International Residential Code® (IRC)
- 2021, 2018, 2015, and 2012 International Energy Conservation Code® (IECC)

2.0 LIMITATIONS

Use of the StableBase Max Yield Open Cell spray foam insulation recognized in this report is subject to the following limitations:

2.1 The insulation shall be installed in accordance with the manufacturer's published installation instructions. They shall also be installed in accordance with this evaluation report and the applicable code, and if there are any conflicts between the manufacturer's published installation instructions and this report, the more restrictive governs.

2.2 Except as indicated in Section 3.3.3 and Section 3.3.6 of this report or by the applicable code, the insulation shall be separated from the interior of the building by a code approved thermal barrier.

2.3 As noted in Section 3.3.3 and 3.3.6 of this report, the insulation shall not exceed the nominal density and thickness.

2.4 During installation, the insulation and the surfaces to which they are applied shall be protected from exposure to weather.

2.5 The contractors that will be installing the insulation shall be approved by Firestable Insulation Company.

2.6 Use of the insulation in areas of "very heavy" termite infestation shall be in accordance with the 2021, 2018, and 2015 IBC Section 2603.8, 2012 IBC Section 2603.9, or IRC Section 318.4, as applicable.

2.7 Labeling and jobsite certification of the insulation and coatings shall comply with IBC Section 2603.2; 2021, 2018, and 2015 IRC Sections N1101.10 and N1101.10.1.1; 2012 IRC Sections N1101.12, N1101.12.1, and N1101.4.1; and IECC Sections C303.1.1 and C303.1.2, as applicable.

2.8 Foam plastic used in plenums as interior finish or interior trim shall comply with Section 2603.7 of the IBC.

3.0 PRODUCT USE

3.1 General: When installed in accordance with Section 3.3 of this report, StableBase Max Yield Open Cell spray foam insulation can be used in wall cavities, floor assemblies or ceiling assemblies, and in attic and crawl spaces as nonstructural thermal insulation material. The spray-applied foam plastic insulation is used in Type V-B construction under the IBC and in dwellings under the IRC.

StableBase Max Yield Open Cell spray foam insulation may be used in Construction Types I, II, III, or IV when installed in accordance with Section 3.4 of this report.

3.2 Design: StableBase Max Yield Open Cell spray foam insulations shall comply with requirements in IECC Sections C402.1 and R402.

3.2.1 Thermal Resistance (R-Values): StableBase Max Yield Open Cell spray foam insulation has a thermal resistance (R-Value) at a mean temperature of 75°F (24°C) as shown in Table 1 of this report.



TABLE 1
Thermal Resistance (R-Value)^{1,2}
(°F·ft²·h/BTU)

Thickness (inch)	R-Value
	StableBase Max Yield Open Cell
1	3.7
2	7.0
3	11
3.5	13
4	14
5	18
5.5	20
6	21
7	25
7.5	27
8	29
9	32
10	36
11	39
12	43
14	50
16	57
18	64

For SI: 1 inch = 25.4 mm, 1°F·ft²·h/Btu = 0.176 110 K·m²/W.

¹ R-Values are calculated based on tested K values at 1-inch and 3.5-inch thicknesses.

² R-Values greater than 10 are rounded to the nearest whole number.

3.2.2 Air Permeance: When tested in accordance with ASTM E2178 at a minimum thickness of 4 inches (102 mm), StableBase Max Yield Open Cell spray foam insulation has an air permeability of less than 0.02 L/s·m² at 75 Pa, meeting the definition of air-impermeable insulation in accordance with the IBC and IRC.

3.2.3 Surface Burning Characteristics: At a maximum thickness of 4 inches (102 mm) and a nominal density of 0.5 pcf (16 kg/m³), the StableBase Max Yield Open Cell spray foam insulation has a flame spread index of 25 or less and a smoke-developed index of 450 or less when tested in accordance with ASTM E84. Thicknesses are not limited for ceiling cavities and wall cavities when covered by a code complying prescriptive thermal barrier, such as minimum ½-inch (12.7 mm) thick gypsum board.

3.3 Installation:

3.3.1 Installation General: The manufacturer’s published installation instructions for StableBase Max Yield Open Cell spray foam insulation and this report shall be available and strictly adhered to at all times on the jobsite during installation.

The spray foam insulation shall be spray-applied on the jobsite using a volumetric positive displacement pump in accordance with the manufacturer’s published installation instructions. StableBase Max Yield Open Cell shall be sprayed in multiple passes having a maximum thickness of 6

inches (152 mm) maximum per pass up to the maximum insulation thickness specified in this report.

The maximum in-service temperature for all areas shall not exceed 180°F (82°C). The spray-applied foam plastic insulation shall not be used in electrical outlets or junction boxes or in continuous contact with rain or water. The spray-applied foam plastic insulations shall be sprayed onto a substrate that is protected and clean from any debris or weather-related conditions during application.

3.3.2 Installation with a Prescriptive Thermal Barrier: StableBase Max Yield Open Cell spray foam insulation shall be separated from the interior by an approved thermal barrier of minimum ½-inch-thick (12.7 mm) gypsum wallboard or an equivalent thermal barrier. When installed in accordance with this section, the spray foam may be any thickness when installed behind a prescriptive thermal barrier. The barrier shall comply with and be installed in accordance with IBC Section 2603.4 or IRC Section R316.4, as applicable.

3.3.3 Installation with an Alternative Thermal Barrier Assembly: The thermal barrier required by IBC Section 2603.4 or IRC section R316.4 may be omitted when all of the following apply:

- a. The thickness of the StableBase Max Yield Open Cell spray foam insulation shall not exceed the values shown in Table 2.
- b. The StableBase Max Yield Open Cell spray foam insulation is coated with a minimum thickness of DC315 Fireproof Paint intumescent coating as described in Table 2 of this report. The coating shall be applied in accordance with the coating manufacturer’s instructions and this report. Surfaces to be coated shall be dry, clean and free of dirt, loose debris and other contaminants that could impact adhesion of the coating.

3.3.4 Installation for Attics and Crawl Spaces: When used in an attic or crawl space where entry is made only for service of utilities, StableBase Max Yield Open Cell spray foam insulation shall be installed in accordance with this section. The insulation shall be separated from the interior of the building by an approved thermal barrier as described in Sections 3.3.2 and 3.3.3 of this report, as applicable. except as noted in Sections 3.3.5 or 3.3.6 of this report.

3.3.5 Installation with a Prescriptive Ignition Barrier: Where entry is made only for the service of utilities, StableBase Max Yield Open Cell spray foam insulation may be installed within attics or crawl spaces with an ignition barrier in accordance with IBC Section 2603.4.1.6 or IRC Sections R316.5.3 and R316.5.4, as applicable. The ignition barrier shall be installed in a manner such that the foam plastic insulation is not exposed and is consistent with the requirements of the type of construction required by the applicable code.



3.3.6 Installation with an Alternative Ignition Barrier Assembly: When installation is in accordance with this section, the ignition barrier described in Section 3.3.5 of this report and as required by Section 2603.4.1.6 of the IBC or Sections R316.5.3 and R316.5.4 of the IRC, as applicable, may be omitted.

3.3.6.1 General: When StableBase Max Yield Open Cell spray foam insulation is installed in attics and crawl spaces without a prescriptive ignition barrier, the following conditions apply:

- a. The thickness of the foam plastic insulation applied to the underside of the top of the space shall not exceed values noted in Table 3 or Section 3.6.2 of this report, as applicable.
- b. The thickness of the foam plastic insulation applied to the vertical surfaces shall not exceed values noted in Table 3 or Section 3.6.2 of this report, as applicable.
- c. Entry is only to service utilities in the attic or crawl space and no storage is permitted.
- d. Attic or crawl space areas cannot be interconnected.
- e. Air from the attic or crawl space cannot be circulated to other parts of the building.
- f. In accordance with 2021 or 2018 IBC Section 1202.2, 2015 or 2012 IBC Section 1203.2, or IRC Section R806, attic ventilation is provided, as applicable.
- g. In accordance with 2021 or 2018 IBC Section 1202.3, IBC Section 1203.3, or IRC Section R408.1, crawl-space ventilation is provided, as applicable.
- h. In accordance with the Uniform Mechanical Code (UMC) Section 701.1 or the International Mechanical Code® (IMC) Section 701, combustion air is provided, as applicable.
- i. Fire-protective coating, noted in this report, is applied in accordance with Table 3.

3.3.7 Unvented Attics: StableBase Max Yield Open Cell spray foam insulation may be installed in unvented attic assemblies and unvented enclosed rafter assemblies in accordance with Section 1202.3 of the 2021 or 2018 IBC, Section 1203.3 of the 2015 IBC, or Section R806.5 of the 2015 and 2012 IRC, as applicable.

3.4 Use in Exterior Walls of Types I, II, III, and IV Construction (IBC)

3.4.1 General: When StableBase Max Yield Open Cell spray foam plastic insulation is used in exterior walls of Types I, II, III, or IV construction of any height, the insulation shall comply with IBC Section 2603.5 and Section 3.4 of this report. Walls required to be fire-resistance-rated construction are beyond the scope of this report and shall comply with IBC Section 2603.5.1.

3.4.2 Complying Exterior Wall Assemblies: Wall assemblies that comply with Section 2603.5 of the IBC and this report that may be used in exterior walls of buildings of

Type I, II, III, or IV construction of any height are described in Tables 4 and 5 of this report.


4.0 PRODUCT DESCRIPTION

StableBase Max Yield Open Cell spray foam insulation is a spray-applied, polyurethane open cell foam plastic and complies as a low-density insulation in accordance with Section 3.1.1 and Table 1 of AC377. The insulation is a two-component spray foam plastic with a nominal in-place density of 0.5 pcf (16 kg/m³).

The spray-applied insulation is mixed in the field by combining a polymeric isocyanate (A component) and a resin blend (B component). The liquid components shall be stored in 55-gallon (208 L) drums at temperatures between 60°F and 90°F (16°C and 32°C). When Component A and Component B are stored in factory-sealed containers at the recommended temperatures, the maximum shelf life is six months.

5.0 IDENTIFICATION

StableBase Max Yield Open Cell spray foam insulation’s containers are identified by the manufacturer’s name (Firestable Insulation Company) address and telephone number, product name, use instructions, density, flame-spread and smoke-development indices, date of manufacture, and evaluation report number (ER-878). The identification may also include either of the IAPMO Uniform Evaluation Service Marks of Conformity as shown below:



IAPMO UES ER-878

6.0 SUBSTANTIATING DATA

6.1 Manufacturer’s descriptive literature and installation instructions.

6.2 Data in accordance with the Acceptance Criteria for Spray-applied Foam Plastic Insulation, ICC-ES AC377, dated April 2020, (editorially revised July 2020) including Appendix X.

6.3 Report of Flammability Testing in accordance with NFPA 286.

6.4 Report of Air Permeance based on ASTM E2178.

6.5 Reports of fire propagation characteristics in accordance with NFPA 285

6.6 Third party engineering analysis for extension of NFPA 285 results.



6.7 Data in accordance with 2019 ICC 1100 Standard for Spray-applied Polyurethane Foam Plastic Insulation.

6.8 Test reports are from laboratories in compliance with ISO/IEC 17025.

7.0 STATEMENT OF RECOGNITION

This evaluation report describes the results of research carried out by IAPMO Uniform Evaluation Service on StableBase Max Yield Open Cell spray foam insulation to assess its conformance to the codes shown in Section 1.0 of this report and documents the product’s certification. Products are manufactured under a quality control program with periodic inspections under the supervision of IAPMO UES.

For additional information about this evaluation report please visit www.uniform-es.org or email at info@uniform-es.org

**TABLE 2
ALTERNATIVE THERMAL BARRIER ASSEMBLIES FOR STABLEBASE MAX YIELD OPEN CELL¹**

FIRE-PROTECTIVE COATING/COVERING			MAXIMUM SPF THICKNESS (inch)	
TYPE	MINIMUM THICKNESS (mils)	THEORETICAL APPLICATION RATE	WALLS AND VERTICAL SURFACES	CEILING AND OVERHEAD SURFACES
DC315 ²	18 WFT (12 DFT)	1.1 gal/100 ft ²	10	12

For SI: 1 inch = 25.4 mm, 1 mil = 0.0254 mm

¹ Fire-protective coatings and coverings shall be applied over all exposed SPF surfaces in accordance with the coating/covering manufacturer’s instructions and this report.

² International Fireproof Technology Inc., recognized in IAPMO UES ER-499.

**TABLE 3
ALTERNATIVE IGNITION BARRIER ASSEMBLIES FOR STABLEBASE MAX YIELD OPEN CELL¹**

FIRE-PROTECTIVE COATING/COVERING			MAXIMUM SPF THICKNESS (inch)	
TYPE	MINIMUM THICKNESS (mils)	THEORETICAL APPLICATION RATE	WALLS AND VERTICAL SURFACES	CEILING AND OVERHEAD SURFACES
DC315 ²	4 WFT (3 DFT)	0.25 gal/100 ft ²	8	14
FS-IB ³	6 WFT (3 DFT)	0.38 gal/100 ft ²	10	15

For SI: 1 inch = 25.4 mm, 1 mil = 0.0254 mm, 1 gallon = 3.785 L, 1 ft² = 0.0929 m²

¹ Fire-protective coatings and coverings shall be applied over all exposed SPF surfaces in accordance with the coating/covering manufacturer’s instructions and this report.

² International Fireproof Technology Inc., recognized in IAPMO UES ER-499.

³ Flame Seal Products, Inc., recognized in IAPMO UES ER-600



TABLE 4 – NFPA 285 COMPLYING EXTERIOR WALL ASSEMBLIES STABLEBASE MAX YIELD OPEN CELL APPLIED IN WALL STUD CAVITY

Wall Component	Material Description
Base Wall (BWS)	Steel Stud Wall - 1 layer of 5/8-inch minimum Type X gypsum wallboard installed on the interior side of minimum 3 3/8-inch deep minimum to 6-inch-deep maximum No. 20 gauge steel studs spaced a maximum of 24 inches on center.
Fire-Stopping in Stud Cavity at Floor Lines	4-inch 4 pcf mineral wool (friction fit or installed with Z-Clips)
Cavity Insulation	StableBase Max Yield Open Cell 1 5/8 inches minimum to 6 inches maximum thickness with a maximum 2-inch air gap for studs ranging from 3 3/8-inch deep minimum to 6-inch-deep maximum.
Exterior Sheathing	Minimum 5/8-inch-thick exterior gypsum sheathing.
Water -resistive Barrier over Base Wall	1) None. 2) Any WRB or alternative vapor barrier that has been approved to be used in a NFPA 285 compliant assembly paired with mineral wool, polyisocyanurate, EPS, or XPS insulation or no exterior insulation for claddings approved for that WRB by an approved evaluation or certification entity.
Exterior Insulation Use either Item 1, 2 or 3	1) None – only where the cladding is listed to be approved with specific water-resistant barrier (WRB). (See Note 1) 2) 2-inch thick minimum 4 pcf mineral fiber insulation allowed for use with any WRB on the base wall surface. (See Note 1) 3) Any polyisocyanurate, EPS or XPS insulation that has been approved (see note 2) to be used in an NFPA 285 compliant assembly paired with the WRBs in Item 2 above and claddings in Item 2 below. (See Note 2)
Exterior Cladding	1) Claddings below may only be used with noncombustible exterior insulation in Item 2 above (mineral fiber) a. Any noncombustible cladding, such as brick, stone, terra cotta, fiber cement, concrete, sheet metal, etc. b. Combustible cladding- Use any cladding that has been successfully tested by the panel manufacturer (or fabricator) via the NFPA 285 test method. (See Note 2) 2) Claddings below may be used with any approved combustible insulation in Exterior Insulation Item 3 above. Any cladding (combustible or noncombustible) that has been approved to be used in an NFPA 285 compliant assembly paired with approved polyisocyanurate, EPS, XPS, or SPF insulation. Each insulation must be specifically approved for the exact cladding types listed in the approval. (See Note 2)
Window/Door Perimeters	Windows and doors shall be framed as required for the base wall. The exterior side of the base wall shall use the approved design for the specific system being considered. (See Note*) *Note: EPS and XPS require specific door/window header and jamb details to be compliant with NFPA 285. Polyisocyanurate and spray foam may require specific header/jamb details. Approvals shall be from an approved evaluation or certification entity for the header/jamb detail required for each insulation type.

For SI: 1 inch = 25.4 mm

Note 1: Examples for use with no exterior insulation or with mineral wool insulation per table above.

1. Any combustible cladding that has passed NFPA 285 testing (examples below)
 - a. NFPA 285 approved MCM/ACM Metal/Aluminum Composite building panels
 - b. NFPA 285 approved stone/aluminum honeycomb composite
 - c. NFPA 285 approved HPL High-Pressure Laminate Panels.
2. Any noncombustible cladding such as (but not limited to):
 - a. Brick - Nominal 4-inch clay brick or veneer with a maximum 2-inch air gap behind the brick. Brick Ties/Anchors 24 inches o.c. (maximum).
 - b. Stucco - 3/4 - inch exterior cement plaster and lath. A secondary water-resistive barrier can be installed between the insulation and lath. The secondary WRB may not be full coverage asphalt or butyl based self-adhering membranes.
 - c. Natural Stone (granite, limestone marble, sandstone) – 2 inch using any installation technique with a 2-inch air gap (max.).
 - d. Artificial Cast Stone – 1 1/2 – inch using any installation technique with a 2-inch air gap (max)
 - e. Terra Cotta Cladding - 1 1/4-inch using any installation technique with a 2-inch air gap (max)
 - f. 1/4-inch (min) fiber cement panels (installed per manufacturer instructions)
 - g. Concrete - 2 inches thick with a 2-inch air gap (max)
 - h. CMU blocks – 4 inches with a maximum 2-inch air gap
 - i. Sheet metals such as aluminum, copper, or zinc – any thickness

Note 2: If the base wall is covered with a combustible WRB/insulation and various claddings (combustible or noncombustible) each insulation/WRB/cladding combination allowed must have explicitly been tested or approved to be used with each other by an approved evaluation or certification entity.